



Premium backfill shall consist of course interlocking aggregate O.D.O.T #304 or Low Strength Mortar backfill, Type 2.

Pipe cover shall consist of course interlocking aggregate no. 57, #5 and #8 (lateral connections only).

Bedding shall consist of course interlocking aggregate No. 57, or 8 for 60" or smaller diameter pipe, for 66" or larger diameter pipe No. 4, #57 and #8 aggregate may also be used.

Bedding for pipe shall conform to ASTM D-2321.

All Material substitutions must be approved by the City Engineer.

Low Strength Mortar Backfill

When the use of flowable fill is directed by the Engineer within the limits of the pavement, the material used shall be Low Strength Mortar Backfill, TYPE 2 per current O.D.O.T. Construction and Material Specifications, except as modified herein.

The use of Foundry Sand or Slag is strictly prohibited.

Notes:

- * Lateral connections to have a minimum bedding depth of 6" coarse aggregate.

A clay dam shall be installed as directed by the City of North Ridgeville inspector for all sanitary and storm connections.

REV No.	DATE	BY	DESCRIPTION
CITY OF NORTH RIDGEVILLE, OHIO DEPARTMENT OF ENGINEERING			
TRENCH DETAIL			
SCALE: NOT TO SCALE			MIS-1
DATE: 10/01/08	DRWN BY: JAB/TEB		

Larry Luffich
CITY OF NORTH RIDGEVILLE, ENGINEER

Rev. 8/20/2014