



All Material substitutions must be approved by the City Engineer.

Bedding shall consist of course interlocking aggregate No. 57, or 8 for 60" or smaller diameter pipe, for 66" or larger diameter pipe No. 4, #57 and #8 aggregate may also be used.

Bedding for pipe shall conform to ASTM D-2321.

Rev. 8/20/2014