



**NOTES:**

1. THE CONTRACTOR SHALL FURNISH HYDRANT BRANCHES HAVING RESTRAINED MECHANICAL JOINTS INCLUDING HYDRANT SHOE. ALL MECHANICAL JOINTS SHALL BE POLYETHYLENE WRAPPED IN ACCORDANCE WITH AWWA C-105/A21.5-88 CLASS "C", METHOD "B".
2. ALL BOLTS AND NUTS FURNISHED WITH RESTRAINED MECHANICAL JOINTS INCLUDING RETAINER OR WEDGE ACTION TYPE GLANDS SHALL BE GRADE 5 HIGH STRENGTH GALVANIZED STEEL OR EQUIVALENT.

CITY ENGINEER:  
CITY OF NORTH RIDGEVILLE, OHIO  
STANDARD CONSTRUCTION DRAWINGS

DATE  
12/1/18

SCALE  
N/A

HYDRANT TYPE A

DETAIL  
WAT-2

PAGE  
1 OF 1