



NOTES:

1. THE CONTRACTOR SHALL FURNISH HYDRANT BRANCHES HAVING RESTRAINED MECHANICAL JOINTS INCLUDING HYDRANT SHOE. ALL MECHANICAL JOINTS SHALL BE POLYETHYLENE WRAPPED IN ACCORDANCE WITH AWWA C-105/A21.5-88 CLASS "C", METHOD "B".
2. ALL BOLTS AND NUTS FURNISHED WITH RESTRAINED MECHANICAL JOINTS INCLUDING RETAINER OR WEDGE ACTION TYPE GLANDS SHALL BE GRADE 5 HIGH STRENGTH GALVANIZED STEEL OR EQUIVALENT.

DETAIL WAT-4	END FLUSHING ASSEMBLY HYDRANT TYPE C		CITY ENGINEER:	CITY OF NORTH RIDGEVILLE, OHIO STANDARD CONSTRUCTION DRAWINGS
	PAGE 1 OF 1	DATE 12/1/18	SCALE N/A	